

| | | |
|---|---|---|
|  | <p>POLICY TYPE: COMMUNITY STANDARDS</p> <p>POLICY TITLE: STORAGE COVERS</p> | <p>Date Approved: July 21, 2010</p> <p>Policy No: CS - 3</p> |
|---|---|---|

In order to maintain a safe environment at the Peaks, and stay in compliance with Fire Marshal requirements:

The Fire Code states:

NFPA 13: 8.9.5.3.2 Sprinklers shall be installed under fixed obstructions over 4 ft (1.2 m) wide such as ducts, decks, open grate flooring, cutting tables, and overhead doors

AFC 6.5.1.5. (1): No obstructions shall be placed so as to interfere with the effectiveness of water discharge from sprinklers

- **Covers must be at least 18” below the closest sprinkler.**
- **Plastic Tarps may be used to cover storage cages.**
- **Tops of the storage cages may not be covered so as to prevent fire water from entering the storage cage.**

Cardboard, metal and wood storage cage covers do not meet the fire code requirements and therefore, must be removed.

Fines relating to Hazards shall apply.